

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. ३३/२४-०९

Dated: 02/09/2024

It is certified that an inspection team headed by Dr. Shivangi Kanchan, M.O. from CHC, Sarnath inspected the St. Lawrence International Shikshan Sansthan, Ledhupur, Sarnath Varanasi on 02/09/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. U1720573S13662794 dated 28/08/2024 of District Health Lab (PHED Lab) certified that the St. Lawrence International Shikshan Sansthan (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 02/09/2025.

Signature with Seal:

Name

Designation

Name & Address of the Office / Department:



साठ स्वाँ केन्द्र सारनाथ
Dr. Shivangi Kanchan
वाराणसी

M.O. PHED

CHC

To

The Manager,

St. Lawrence International Shikshan

Sansthan, Ledhupur, Sarnath,

Varanasi

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Jal Jeevan Mission

Har Ghar Jal



District Level Water Analysis Laboratory, U.P Jal Nigam (Urban), Varanasi.

Sarnath water works campus U.P Jal Nigam, Village -- Sarnath, Post- Sarnath, Dist- Varanasi (Test Address only)

Test report

Sample ID:

U1720573513662794

User Information

Name: St. Lawrence International Shikshan Sanssthan, Ledhupur Mobile: 8543990990
Email: yadvpashupati3@gmail.com Pin Code: 221007
Full Address: Ledhupur, Sarnath, District- Varanasi, State- Uttar Pradesh

Sample description

Source of Sample: Tube well / Bore well / Well Village: Ledhupur
Gram Panchayat: Ashapur Block: Chirai Gaon
District: Varanasi State: Uttar Pradesh
Address: Remarks:
Latitude: Longitude:

Date & time of sample collection Date & time of sample received in lab Date & time of sample analysed Date & time of report generation

26.08.2024 | 02:17:00 PM

26.08.2024 | 02:27:00 PM

28.08.2024 | 02:56:00 PM

28.08.2024 | 02:56:00 PM

Test results

Sr. No.	Parameter tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate standard) as per BIS 10500	Test result value	Remarks
1	Calcium (as Ca)	mg/l	75	200	49.600	
2	Chloride (as Cl)	mg/l	250	1000	56.000	
3	Colour	Hazen units	5	15	8.000	

Sr No	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
4	Conductivity	micromhos per centimeter / microsiemens per centimeter	NA	NA	716.300	
5	Fluoride (as F)	mg/l	1	1.5	0.440	
6	Free residual Chlorine	mg/l	0.2	1	0.000	
7	Iron (As Fe)	mg/l	1	No Relaxation	0.260	
8	Magnesium (As Mg)	mg/l	30	100	36.480	
9	Nitrate (as NO3)	mg/l	45	No Relaxation	11.740	
10	Odour	NA	Agreeable	Agreeable	0.000	
11	pH	NA	6.5-8.5	No Relaxation	7.130	
12	Sulphate (as SO4)	mg/l	200	400	27.580	
13	Taste	NA	Agreeable	Agreeable	0.000	
14	TDS	mg/l	500	2000	358.000	
15	Total Alkalinity (as Calcium Carbonate)	mg/l	200	600	308.000	
16	Total Arsenic (As As)	mg/l	0.01	No Relaxation	0.000	
17	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
18	Total Hardness (As CaCO3)	mg/l	200	600	276.000	
19	Turbidity	NTU	1	5	2.630	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Dheeraj Tripathi

Authorised signatory

Dheeraj Kumar Tripathi (Test Lab Incharge)

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC Copyright © Copy NJJM 2022

Print